

INDIAN ASSOCIATION FOR THE CULTIVATION OF SCIENCE
2A & 2B, Raja S.C. Mullick Road, Jadavpur, Kolkata-700032

Ref. No. IACS/MS/SR/2017-18/1

Date : 24-07-2017

Corrigendum Notice No. I

NIT No. IACS/MS/SR/2017-18/30, Date : 20-07-2017

Additional Technical Specification for the 40 kVA UPS :

Page 2 :

1. Built-in isolation transformer in the inverter output
2. Phase reversal facility
3. The supplier company should be ISO 9001 and ISO 50001 certified.

Acting Registrar