

Scope of work					
Name of work: Supply, replacement and recommissioning of the defective smoke detectors and LCD touch screen in respect of the addressable BOSCH make fire detection & alarm system installed at the Main Building of IACS Jadavpur					
SI No.	Item description	Quantity	Unit	Rate	Amount
1)	Supply, installation, testing and commissioning of intelligent, analog, addressable, photo thermal smoke cum heat detector complete with mounting base, as required and compatible with the existing BOSCH make system.	80	Nos.		
	Make: BOSCH				
2)	Supply, installation, testing and commissioning the touch screen LCD display (HMI) of BOSCH make FPE-8000-SPC addressable fire control panel	1	Job		
a)	Re-programming and simulation with original BOSCH software in order to incorporate the change in devices address.				
b)	Miscellaneous change in settings pertaining to fine tuning the addressing of the installed devices by AUTORUN data.				
	Make: BOSCH				
			Total		
NOTE:The quoted rate shall be inclusive of all taxes & duties, levies, cess etc i/c GST also. Nothing extra will be paid to the Contractor except the accepted rate.					
GST No:					
HSN/SAC code:					
CGST@ 9% considered in the above BOQ					
SGST@ 9%Considered in the above BOQ					